

水质测试结果

测试项目	进水电导率 (EC)	进水电导率水温	进水溶解性总固体值 (TDS)	出水电导率	出水电导率水温	出水溶解性总固体值
自来水				52.8 us	17.30°	26.7 ppm
纺织	5.28 ms	22.60°	2640 ppm	5.37 us	20.20°	2.59 ppm
羊毛厂-样品A	6.73 ms	20.60°	3370 ppm	220.5 us	18.0°	110.4 ppm
羊毛厂-样品B	3.36 ms	22.40°	1820 ppm	249.6 us	21.60°	124.9 ppm
染料水	8.65 ms	21.0°	4290 ppm	65.9 us	25.30°	23.8 ppm
30%盐水	242.0 ms	12.40°	121100 ppm	27.5 us	11.90°	15.6 ppm
20%盐水	219.4 ms	19.90°	109700 ppm	9.54 us	16.0°	4.47 ppm
5%盐水	82.9 ms	19.10°	40400 ppm	15.11 us	15.10°	7.79 ppm
Port Phillip海湾海水	45.9 ms	18.10°	22800 ppm	9.05 us	15.10°	4.38 ppm
Port Phillip海湾海水	41.6 ms	15.60°	20800 ppm	13.95 us	14.60°	10.85 ppm
酿酒厂	7.06 ms	17.90°	3530 ppm	7.15 us	14.90°	3.36 ppm
赛马场	7.16 ms	18.30°	3580 ppm	10.2 us	15.70°	5.3 ppm
海洋馆试验水	45.0 ms	19.80°	22600 ppm	8.37 us	20.50°	4.46 ppm
纺织 (印染废水)	2.65 ms	25.0°	1327 ppm	81.1 us	25.90°	40.6 ppm
澳洲纺织厂	4.86 ms	26.10°	2410 ppm	54.4 us	26.60°	27.3 ppm
瓶装水				94.4 us	11.30°	47.2 ppm
铝冶炼厂 - CPL 净化器 0283	7.98 ms	24.10°	3990 ppm	47.9 us	23.90°	24.0 ppm
铝冶炼厂 - RO 处理厂废水	3.02 ms	23.90°	1510 ppm	5.0 us	24.10°	2.56 ppm
铝冶炼厂 - 科里欧湾 (Corio Bay) 海水	63.0 ms	24.40°	31400 ppm	16.0 us	24.30°	6.0 ppm
铝冶炼厂 - 钢锭厂废水	852 us	20.10°	426 ppm	6.45 us	20.30°	3.5 ppm
铸成磨具厂 DAF泥状污水 0287	1046 us	23.10°	523 ppm	26.0 us	23.10°	13.0 ppm
纺织公司	9.46 ms	17.70°	4740 ppm	17.80 us	17.20°	9.9 ppm
RO处理后的高浓度废渣	28.90 ms	20.30°	14420 ppm	147.3 us	21.10°	73.9 ppm
TFS 固体清除后	8.13 ms	17.20°	4070 ppm	81.6 us	17.30°	41.0 ppm
铝冶炼厂冷却塔排污水 Anglesea 发电站	4.95 ms	17.10°	2480 ppm	34.2 us	17.0°	17.6 ppm
铝冶炼厂灰沉淀池污水样本 Anglesea 1 号发电站	8.36 ms	25.0°	4180 ppm	185.1 us	23.10°	93.3 ppm
铝冶炼厂 - Sims Aluminium 工厂铝盐液	235.1 ms	22.50°	117100 ppm	1015 us	21.60°	510 ppm
染棉初步处理期的高浓度水	9.55 ms	18.10°	4770 ppm	67.4 us	18.50°	33.9 ppm
工业废水	1862 us	19.0°	932 ppm	108.7 us	18.50°	54.8 ppm